

Minnesota In-State Water Energy Nexus Retreat

August 3, 2018

National Governors Association Center for Best Practices





Select AHWilder-Public-Wireless Network

Open browser

If website security select continue to this website

On log in – select don't have an account

Enter fist and last name

Click submit

When account created click okay

Accept terms and conditions

About NGA

Office of Government Relations

Center for Best Practices

Collective voice of governors in Washington D.C.

- Builds consensus on Federal issues
- National policy focus

- Comparative policy shop for state level efforts
- Provides governors and staff technical assistance and policy guidance

Office of Management Consulting & Training

- Internal management consultants
- Training and advice for governors, chiefs of staff, legal counsels, policy directors schedulers, spouses



2018 Technical Assistance

Energy Assurance Grid Ex Workshop Executive Order Roadmap State Resiliency Assessment & Planning Tool State Resiliency Retreats Energy Assurance Webinars	Chair's Initiative: Ahead of the Curve: Innovation Governors Energy Summit & Transportation Summit Story Maps and Policy Roadmaps Podcasts	Smarter States, Smarter Communities Learning Lab State Specific Support
Power Sector Modernization Policy Academy State Specific Support	Technical Assistance on Demand Research Policy Memos Consultation	Transportation Modernization Traffic Safety Learning Labs Traffic Safety Roadmap Electric Vehicle (EV) Regional Workshops
Energy Efficiency Lead By Example Workshop Experts Roundtable Water- Energy Nexus Retreats	Nuclear Weapons Waste Federal Facilities Task Force Summer Meeting Intergovernmental Fall Meeting Webinar Series	Water Policy Learning Network Water Policy Institute Webinar Series Water- Energy Nexus Retreats

ENVIRONMENT, ENERGY & TRANSPORTATION DIVISION

NGASES ASSOCIATION

Water Energy Nexus Retreat Core Team

State of Minnesota

Jessica Burdette, State Energy Office Manager, Minn. Dept. of Commerce

Lindsay Anderson, Energy Project Manager, Minn. Dept of Commerce

Aaron Luckstein, Manager, Municipal Wastewater, Minnesota Pollution Control Agency

Will Seuffert, Director, Environmental Quality Board

Randy Thorson, Principal Engineer, Minnesota Pollution Control Agency

Anna Henderson, Water Advisor, Governors' Office

National Governors Association

Bevin Buchheister, Senior Policy Analyst

Patricio Portillo, Policy Analyst

Brielle Stander, Program Assistant



Introductions

- In 15 seconds or less, please briefly state your:
 - Name
 - Affiliation
 - Role/Title



Agenda

- Welcome & Introductions
- Background & Determining State objectives
- Local Perspective and Opportunities for Progress
 - Policy
 - Funding & Finance
 - Technical Assistance
 - Workforce Development
- Lunch & Keynote
- Best Practices Presentation & Discussion
 - Technical Assistance
 - Policy
 - Funding & financing
 - Workforce Development
- Roundtable Discussion
- Develop Action Plan & Wrap Up





Background & Determining State Objectives

Shannon Lotthammer, Assistant Commissioner, Water Policy/Agriculture Liaison, Minnesota Pollution Control Agency




Advancing Efficiencies in the Water-Energy Nexus



Shannon Lotthammer | Assistant Commissioner

March 6, 2018

MN: Innovation, Leadership and Action




Existing Programs/Actions (Examples)

- Next Generation Energy Act goals
- Grant to increase energy efficiency in small and mid-sized WWTPs
- Buildings, Benchmarks and Beyond
- Individual facility efforts

Challenges – and Opportunities!

- Infrastructure investment needs
- Working across sectors and areas of expertise
- Workforce changes
- Shared goals



Today's Retreat



- Learn from each other
- Explore opportunities
- Identify next steps and an Action Plan

Thank you (in advance) for a great day!

FORMOR

HON

MON OP



The Local Perspective and Opportunities for Progress

Policy: Anna Henderson, Water Advisor, Office of Governor Mark Dayton

Funding & Financing: Jeff Freeman, Executive Director, Minnesota Public Facilities Authority


Technical Assistance: Laura M. Babcock, Director, Minnesota Technical Assistance Program

Workforce Development: Wade Klingsporn, President, Minnesota Wastewater Operators Association & Instructure, Vermilion Community College

Minnesota's Energy and Water Policy




Anna Henderson, PhD Senior Policy Advisor Office of Governor Mark Dayton EQB





BWSR

Minnesota Water Use 2016





Minnesota is a Headwaters State






The most efficient strategy is pollution prevention: Targeting protection of key lands is the safest option for public health and the cheapest option.





Minnesota Getting Much Warmer and Wetter








The Next Generation Energy Act of 2007

(Minn. Stat. § 216H.02)



- 2015 reduction goal of 15 percent
- 2025 reduction goal of 30 percent
- 2050 reduction goal of 80 percent


*baseline of 2005




 Renewable Energy Standard (RES) of 25% renewable generation by 2025

Energy Efficiency ۲ **Resource Standard (EERS)** requires electric and natural gas utilities to offer costumers cost effective energy conservation and efficiency programs to achieve an annual energy savings equal to 1.5% of their retail energy sales.

Percent of Achieving 2030 Target




Burnsville greenhouse gas emissions 2017




Orange Environmental report, 2018

Burnsville Electricity Consumption, 2005-2017




Orange Environmental report, 2018


St. Louis Park, Minnesota



Economic and Environmental Win-Win!




Clean Energy Jobs



Water Technology Jobs









Thanks

Community PWS with source groundwater above 10 mg/L (1/1/2011 to current)	Population (2016)	Past and Potential Future Actions	Estimated Capital Cost per Household (2016 dollars)
Adrian	1211	Wells sealed and treatment plant built.	\$3,400
Brookhaven Development, Louisville Township, Scott County	45	Potential future new well.	\$3,400
Chandler	270	Potential future hookup to LPRWS*.	Unknown
Clear Lake	525	Treatment plant to be replaced.	\$7,900
Cold Spring	4,053	Potential new wells.	\$1,100
Edgerton	1,171	Treatment plant built.	\$3,500
Ellsworth	456	Well sealed and treatment plant built.	\$3,600
Hastings	22,335	Treatment plant built.	\$430
Leota	209	Interconnect to LPRWS* installed.	Unknown
Lincoln-Pipestone Rural Water System (LPRWS)	13,010	Potential blending wells and treatment plant improvements.	\$180
Park Rapids	3,808	Wells sealed, new well constructed, and treatment plant built.	\$3,100
Randall	650	future potential treatment plant	\$7,400
Rock County Rural Water System	2,256	Transmission main built to blend wells.	\$46
Saint Peter	11,758	Treatment plant built.	\$1,700
Sundsruds Court, Todd Township, Wadena County	40	Treatment installed.	\$450

Greenhouse Gas Emissions by Sector (CO2-e short tons)



Historic greenhouse gas emissions (1990-2011) and projected emissions (2012-2030) are shown by economic sector. To be on track in 2030 for meeting Next Generation Energy Act Goals, an additional 53 million CO_2 -equivalent short tons (CO_2 -e) a year need to be reduced beyond business as usual. (Data source: Minnesota Pollution Control Agency, September 2013).



MINNESOTA PUBLIC FACILITIES AUTHORITY


The Water-Energy Nexus

In-State Retreat, August 3, 2018


Jeff Freeman, Minnesota Public Facilities Authority

Water Infrastructure Needs

Wastewater - \$4.9 billion over 20 years



Drinking Water - \$7.4 billion over 20 years





Funding for Water Infrastructure Projects

- State loan and grant programs (Public Facilities Authority)
 - Clean Water and Drinking Water State Revolving Funds (loans)
 - Water Infrastructure Fund (WIF) grants
 - Point Source Implementation Grants (PSIG)
- USDA Rural Development grants and loans (federal)
- Small Cities Development Program (federal, admin by DEED)
- Local government financing (private bond market)
 - PFA credit enhancement program can help cities get higher bond rating (one notch below state)



State Funding Framework

- PFA funding is based on low interest SRF loans and targeted grants focused on affordability (WIF) and treatment requirements (PSIG)
- Project priority lists (PPL) rank projects based on age and condition of existing infrastructure and water quality and public health criteria
 - MPCA wastewater and stormwater projects
 - MDH drinking water projects
- PFA annual Intended Use Plans (IUPs) identify "fundable range"
 - Cities with projects ranked in the upper 2/3 3/4 on the PPL can be assured of at least low interest loans when ready for construction



Project Review

- Wastewater projects must submit a facilities plan to MPCA that evaluates system needs and alternatives, including a cost-effectiveness analysis
 - MPCA cost and effectiveness guidelines discuss need to include consideration of:
 - Energy conservation opportunities
 - Renewable energy opportunities
 - Solar, wind, biogass, combined heat and power
 - Water reuse options
 - Guidelines also reference Minnesota's B3 tools to identify energy conservation measures for wastewater systems and provide energy performance benchmarks



Conclusion

- PFA funding is available for most large water infrastructure projects
 - Project costs for energy improvements are eligible for PFA funding
 - CWSRF federal funds include a Green Project Reserve and possibility of a 25% principal forgiveness grant up to \$1,000,000 for eligible project costs
- Smaller scale capital and operational improvement projects may often be funded by cities themselves
- Cities may be reluctant to try new technology due to cost, regulatory pressures, and the need to provide continuous 24/7/365 service
- Energy related outreach and training for public works directors, operators, consulting engineers is critical



NATIONAL GOVERNORS ASSOCIATION

Minnesota Water-Energy In-State Retreat Technical Assistance

Laura Babcock August 3, 2018

UNIVERSITY OF MINNESOTA Driven to Discoversm

Minnesota Technical Assistance Program

Strengthening Minnesota businesses by improving efficiency while saving money through energy, water, and waste prevention.





University of Minnesota

Technical Assistance at the Water-Energy Nexus

- Goals of Technical Assistance
 - Assess current state
 - Develop future state
 - Support transition
 - Optimize resource utilization and impact





Technical Assistance - Wastewater Facilities



Objective: Improve WWTP energy efficiency

2% of ALL electric

energy use in U.S.

 25-40% of WWTP operating budget





MINNESOTA POLLUTION CONTROL AGENCY

Energy Efficiency in Water and Wastewater Facilities , EPA 2013 Statewide Assessment of Energy Use by the Municipal Water and Wastewater Sector, NYSERDA 2008

Show - Comparative Energy Use

- Benchmarking
 - Compare operations internally and externally

- Identify improvement opportunities
- Monitor change
- Track progress



Energy Star[®] Portfolio Manager

- Supported by Energy Star[®]
- Compares facilities nationally
- Requires:
 - Flow, influent/effluent BOD
 - Utility information
- Accounts for climate and operations

Effluent Flow (million gal/day)	Electricity Cost (\$0.10/kWh)	Energy Star [®] Score*
0.52	\$142,000	5
0.57	\$45,000	57

*Score estimated using Energy Star[®] algorithm



B3 Wastewater Tool

- WWTP module in Minnesota B3 Benchmarking
 - Engage facilities in energy efficiency
 - Align with state benchmarking tool
 - Provide a forum to track energy performance
 - Use best features of ESPM without size limits
- More information
 - Demonstration Video <u>z.umn.edu/WWB3</u>
 - http://mn.b3benchmarking.com/Documents/B3_WWTP_Overview.pdf


Minnesota Department of Commerce and The Weidt Group







Help – Identify and Implement Typical WWTP Energy Profile




Water and Wastewater Industry Energy Best Practices Guidebook, Focus on Energy, 2006

University of Minnesota



Efficiency Opportunities

Aeration Energy Costs vs. DO





Source: Tom Jenkins, JenTech Inc.

Energy Assessment

Pop. 2,160, Treating 0.28 MGD



Basin DO was 9.2ppm

- Opportunities
 - Use fewer aeration basins
 - Turn down blower speeds
 - Use smaller blower
- Implemented Savings
 - 220,000kWh electricity per year

- \$20,000 annual operation cost
- Estimated Score 16 to 29



Energy Assessment

Pop. 2,470, Treating 0.41 MGD



Reduce the annual energy costs


- Opportunities
 - Turn down biosolids airflow
 - Turn off biosolids airflow after emptying
 - Tune biosolids blower cycle time
- Implemented Savings
 - ~180,000kWh electricity per year
 - ~\$11,700 annual operation cost
- Estimated Score 18 to 52





Project Results

- 53 Efficiency recommendations
 - 35 Operational changes
 - 18 Capital changes
- Total Energy Potential
 - 5.5 million kWh electricity
 - 600 Minnesota homes
- High implementation potential



University of Minnesota

Next Steps - Resources for Implementation



- MnTAP Intern Projects
 - Established program
 - Experiential learning opportunities
 - Provide needed site resources for implementation
- Operations Cohort Training
 - Developing program
 - Training WWTP staff on E2
 - Implementation support through peer learning



Next Steps - Biogas Utilization

- Assess WWTP potential for Combined Heat & Power (CHP)
- Indicators for CHP feasibility
 - Energy efficiency complete
 - Generates biogas
 - Feedstocks available
 - Target flow rate >5 MGD

MIDWEST

St. Cloud (NEW) Nutrients, Energy & Water Recovery Facility





U.S. DEPARTMENT OF ENERGY CHP Technical Assistance Partnerships

Distributed Generation Opportunity for MN

- 64 mechanical plants with anaerobic digestion
- •<10 facilities with flow >5 MGD
- Explore CHP opportunity for flow >1 MGD and high BOD*
- 26 Minnesota facilities treat
 > 2000 lb BOD/day



UNIVERSITY OF MINNESOTA

*https://www.epa.gov/sites/production/files/2015-07/documents/opportunities_for_combined_heat_and_power_at_wastewater_treatment_facilities_market_analysis_and_lessons_from_the_field.pdf,



CHP Screening Results


- Level 1 assessments to determine site potential for CHP projects
- Reasonable CHP payback potential (4-10 yrs) at smaller facilities
- Potential benefit to scope anaerobic digestion and CHP at smaller facilities with high load

MIDWEST

Site	Flow	BOD Removal (lb/day)	CHP Simple Payback
1	3.2 MGD	12,400	3.9 yr
2	1.5 MGD	2,500	9.1 yr
3	3.4 MGD	9,700	4.2 yr
4	1.2 MGD	1,200	4.8 yr

U.S. DEPARTMENT OF ENERGY CHP Technical Assistance Partnerships

Technical Assistance at the Water-Energy Nexus







Strategies that work!

- Show
 - Benchmarking
- Help
 - Assessments
- Next Steps
 - Implement efficiency
 - Biogas utilization



UNIVERSITY OF MINNESOTA

z.umn.edu/wwee

Minnesota & National Governors Association Water-Energy Nexus Retreat

Wade Klingsporn

August 3, 2018



Background and Current Status of the MN Water/Wastewater Workforce

- Availability of staff: Major limitation?
 - Entry level staff
 - Supervisory level staff
- Availability of jobs: Rarely a shortage
 - League of Minnesota Cities (28)
 - MN Rural Water Association (10)
- Age distribution of workforce: Lack of data in MN



The Workforce Need!

• According to the National Rural Water Association:

"It takes more than **380,000 highly skilled** water and wastewater personnel to ensure the public supply of safe drinking water and to protect our lakes, streams and groundwater".

"Over the next decade, the water sector is expected to lose between **30 and 50 percent** of the workforce to retirement. Many of these employees have worked at the same utility for the majority of their careers, and they will depart with decades of valuable institutional knowledge".



Availability of Staff


- Entry level staff:
 - Water/Wastewater Operations degrees (Vermilion Community College, St. Cloud Technical College)
 - Operator in Training programs (WLSSD, MetCouncil)
 - Apprenticeship program (NRWA)
- Supervisory level staff:
 - Replacing retiring upper-level staff
 - Small rural towns
 - Contractors???





Demographics

• MPCA Wastewater Operations Specialists and Collections (S) staff:



Demographics

- MDH Water Operations Specialists
 - A: 250
 - B: 553
 - C: 1238D: 1236



Workforce Development Programs Continued Education

- MANY opportunities!
- MRWA lists 66 separate training sessions (2018/2019):
 - MRWA
 - MDH
 - Minnesota Training Coalition
 - Determines need and content and assessment of former training events
 - AWWA
 - MPCA
 - VCC (SWAMP)
 - MWOA
 - CSWEA
 - Topics: SDWA, Wastewater, Water, Collections, Certification Refreshers, Small Systems, Pumps, Bioslids, etc.



Workforce Development Programs *Continued Education*

- MPCA Training attendance (2018) Years of Experience:
 - **0-5:** 30%
 - **5-10:** 25%
 - **10-15:** 8%
 - **15-20:** 16%
 - **20-25:** 6%
 - **25-30:** 5%
 - **30+:** 10%



Trends

- Aging workforce especially in the Supervisory positions
 - Loss of knowledge
- Less high school students going on into trades education/field
 - Where will the workforce come from?

• Focus is starting to shift to "Optimization"

- Doing more with less
 - Reduction in pollution discharge
 - Reduction in cost (less chemicals, more efficiency)
- 2 separate projects (MRWA and MPCA)
 - MRWA and MNTAP: Pond Optimization
 - MPCA: Wastewater Treatment Optimization



Conclusion

- Need to make career more appealing:
 - Wages/Benefits
 - Job stability
 - Environmental stewardship
 - Diverse workforce
- Shift focus from meeting limits to energy efficiency, reduction in pollution, and reduced operating costs







Questions?

Wade Klingsporn Vermilion Community College <u>wade.Klingsporn@vcc.edu</u> 218.235.2145 (Office) 218.341.4168 (Cell)





Lunch & Keynote

Tracy Hodel, Assistant Utilities Director, City of St. Cloud Minnesota

Patrick Shea, Public Services Director, City of St. Cloud Minnesota





Water & Energy Innovations

at the St. Cloud NEW (Nutrient, Energy & Water) Recovery Facility



HYDRO - 8.86 MW - 47M kWh

DRINKING WATER

- Lime Softening - 24 MGD

STORMWATER

- 190 miles
- 8,000 catch basins
- 212 outfalls

RESOURCE RECOVERY

Renewable
 Energy
 Production
 - 18 MGD

ST.CLOUD GREATER PUBLIC UTILITIES

St. Cloud NEW (Nutrient, Energy & Water) Recovery Facility



OVERVIEW



- Energy Data
- R2E2 Master Plan
- Energy Efficiency
- Biofuel Recovery
- Solar
- Nutrient Recovery & Reuse

You Can't Manage What You Don't Measure



B3 Benchmarking



DEINCHIVIAKKIING Water Mode Meter Sea City of St. Cloud ⑤ X≣ Ū Ľ Wastewater Treatment Plant Schmidt Rink Waste Water Treatment P Saint Cloud, MN 56301 Seberger Park REPORTS IMPROVEMENTS SUMMARY BENCHMARK PEER COMPARISON ENERGY STAR BASELINE Southside Park O Monthly Continuous Jan 🗸 2015 🗸 \checkmark ○None Southwood Park \checkmark Electric Monthly Yr Over Yr OBenchmark Spalt Park -- TO --Baseline Weather Normalize Units: OAnnual Baseline \sim Dec 💙 2017 🗸 Native Units Show Events Street Lights-East Central O Rolling 12 Mo Avg 🛗 Jan 2013 - Dec 2013 Show Completeness Street Lights-Stearns Elec ⊖Target Plot Air Temperature Street Lights-Xcel OEvent 📄 Talahi Park Monthly Year Over Year Traffic Signal-Stearns Elec Traffic Signal-Xcel Electric, Baseline Weather Normalized 600,000 Water Towers 2015 Water Treatment Facility 2016 400,000 Westwood Park kWh 2017 Whitney Concessions Baseline 200,000 🞚 Whitney Garage Whitney Park K M 🔢 Whitney Rec Center III Whitney Senior Center Consumption Summary By Year Wilson Park Days Complete SF Actual kWh Baseline kWh Change From Baseline kWh Period % Change Total Cost Cost Rate \$/kWi Woodland Hills Park

Emergency Mgmt Sirens Whitney Senior Center Central Services Fire Stations Paramount Theater City Hall Traffic Signals Parking Ramps St. Cloud Airport Park Department Street Lighting Police Headquarters **Rivers Edge Regional Library** Municipal Athletic Center Aquatics Center Water & Towers Wastewater & Liftstations

130,876 234,026 398,2 427, 483 58 5

2017 ELECTRICAL CONSUMPTION

(KILOWATT-HOURS)

.80				(
	Energy Source		2017 Total			
,995 E	ectric		28,800,000 kWh	\$3,1	75,000	
1,810				I		
8,410						
845,616	345,616					
899,795	899,795		9 ⁰ 1 8 2			
1,116,	1,116,044					
1,175	1,175,398					
1	1,441,040 1,659,960 1,889,524		7 3			
			° 5 4			
		2,748,802				
	1,496,100					
				5,640,819)	
					6,979,947	

R2E2 MASTER PLAN

Energy Efficiency

Biofuel Recovery


Solar

Resource Recovery & Reuse

St. Cloud Nutrient, Energy & Water Recovery Facility

Producing Clean Water, Renewable Energy, and Recovering Nutrients

The St. Cloud NEW Recovery Facility is a leader in innovative, cost-effective, and sustainable practices, producing renewable energy, recovering nutrients, and sending clean water back to the environment. The NEW Recovery Facility makes the City of St. Cloud GREATER, converting waste products to renewable resources.



ENERGY EFFICIENCY

RESOURCES



MN TAP -Internship Program



Xcel Energy – Process Efficiency Program

ENERGY EFFICIENCY



Energy Efficiency Improvements & Upgrades



164


Homes' Electricity

(Use for one year)




1,200,000 Pounds of Coal **2,700,000** Miles Driven (By a passenger vehicle)

ENERGY & COST SAVINGS



BIOFUEL RECOVERY




BIOFUEL RECOVERY



Biofuel Energy Production – kWh

(Aug 17 – Jul 18 = 4,500,000 kWh)



■ kWh

ENERGY & COST SAVINGS (EFFICIENCY + PRODUCTION)

40,000,000 + 122,000,000 = **162,000,000 kWh's**



\$3,500,000 + \$10,000,000 = **\$13,500,000**



GREENHOUSE GAS EQUIVALENCY



266,000,000 pounds of carbon dioxide emissions











Annual Pro-CITY'S FIRST SC CITY'S FIRST BE

Annual Production – 340,000 kWh's

CITY'S FIRST SOLAR INSTALL – 20KW ROOFTOP CITY'S FIRST BEHIND THE METER INSTALL – 220KW




% **RENEWABLE**



NUTRIENT RECOVERY & REUSE PROJECT

NR2 PROJECT TIMELINE



CORE AREAS

POLICY

• **BIDDING LAWS**

FUNDING & FINANCING

- GRANTS
 PERFORMANCE CONTRACTING
- PFA LOAN
 APPLICATION
 PROCESS
- TIMING; SOLAR RELATED TAX CREDITS
- EQUIPMENT SITE VISITS

TECHNICAL ASSISTANCE

- "ENERGY" EDUCATION
- UTILITY BILL
- ENERGY DATA MANAGEMENT
- B3
 - BENCHMARKING IMPROVEMENTS
- UTILITY
 ASSISTANCE PROVIDE
 AUTOMATIC DATA
 ENTRY

WORKFORCE DEVELOPMENT

- DIVERSITY IN EDUCATION & EXPERIENCE
- TECHNOLOGY & COMPLEXITY

CENTRAL STATES WATER ENVIRONMENT ASSOCIATION



MN SECTION RESOURCE RECOVERY & ENERGY (R2E) COMMITTEE

- Resource for WWTF's & Collection Systems
- Minnesota Network
- Focus on Sustainable Technology
- Planning for the Future
- For Operators, Supervisors, and Others
- Large and Small Utilities
- <u>http://cswea.org/minnesota/</u>
- Recognition Opportunities





Technology Scans



LIFT Link





SEE IT










OPPORTUNITY & IMPACT

Energy Potential contained in wastewater, biosolids, biogases exceeds by 10 times the energy used to treat Resource Recovery Facilities collectively could potentially meet 10 percent of the national electricity demand

OPPORTUNITY & IMPACT



FOR OUR FUTURE GENERATIONS



THANK YOU & QUESTIONS



Patrick Shea

Public Services Director 320.255.7225

Tracy Hodel

Assistant Public Utilities Director 320.255.7226



Technical Assistance: Clifford P. Haefke, Director, Energy Resources Center, University of Illinois at Chicago

Policy: Megan Levy, Local Energy Programs Manager, Wisconsin Office of Energy Innovation

Funding: Alice Dasek, Energy Efficiency & Renewable Energy, U.S. Department of Energy

Workforce Development: Dave Kuzminski, Coordinator, Water & People Program/Water Boot Camp, Hartford Connecticut

CHP and Energy Efficiency Technical Assistance Resources for the Wastewater Market Sector


National Governors Association Minnesota Water-Energy Nexus In-State Retreat Saint Paul, Minnesota August 3, 2018



Agenda

- US DOE CHP Technical Assistance Partnerships
- US DOE Industrial Assessment Centers
- US DOE Better Buildings Sustainable Wastewater Infrastructure of the Future (SWIFt) Accelerator
- Example Illinois Programs (past and present)





THE ROAD TO ENERGY IMPROVEMENT

Several U.S. Department of Energy programs increase focus on energy-water nexus to aid water sector and reduce energy use

Cliff Haefke

n 2014, the U.S. Department of Energy (DOE) released the report, *The Water-Energy Nexus: Challenges and Opportunities*, which details the intimate relationship between the water and energy sectors. Since then, several In addition to examining process equipment and operational and energy-management procedures, IAC teams also can provide information and general guidance on cybersecurity vulnerability threats to industrial facilities and WRRFs.

Source: Water & Environment Technology Magazine, April 2018, Volume 30, Number 4.



CHP Technical Assistance Partnerships

DOE CHP Technical Assistance Partnerships (CHP TAPs)

• End User Engagement

Partner with strategic End Users to advance technical solutions using CHP as a cost effective and resilient way to ensure American competitiveness, utilize local fuels and enhance energy security. CHP TAPs offer fact-based, nonbiased engineering support to manufacturing, commercial, institutional and federal facilities and campuses.

Stakeholder Engagement

Engage with strategic Stakeholders, including regulators, utilities, and policy makers, to identify and reduce the barriers to using CHP to advance regional efficiency, promote energy independence and enhance the nation's resilient grid. CHP TAPs provide fact-based, non-biased education to advance sound CHP programs and policies.

• Technical Services


As leading experts in CHP (as well as microgrids, heat to power, and district energy) the CHP TAPs work with sites to screen for CHP opportunities as well as provide advanced services to maximize the economic impact and reduce the risk of CHP from initial CHP screening to installation.



www.energy.gov/chp



DOE CHP Technical Assistance Partnerships (CHP TAPs)



DOE CHP Deployment Program Contacts www.energy.gov/CHPTAP

Tarla T. Toomer, Ph.D. CHP Deployment Manager Office of Energy Efficiency and Renewable Energy U.S. Department of Energy

Tarla.Toomer@ee.doe.gov

Patti Garland


DOE CHP TAP Coordinator [contractor] Office of Energy Efficiency and Renewable Energy U.S. Department of Energy Patricia.Garland@ee.doe.gov

Ted Bronson

DOE CHP TAP Coordinator [contractor] Office of Energy Efficiency and Renewable Energy U.S. Department of Energy tbronson@peaonline.com

CHP: A Key Part of Our Energy Future

- Form of Distributed Generation (DG)
- An integrated system
- Located at or near a building / facility
- Provides at least a portion of the electrical load and
- Uses thermal energy for:
 - Space Heating / Cooling
 - Process Heating / Cooling
 - \circ Dehumidification



Source: www.energy.gov/chp



What Are the Benefits of CHP?

- CHP is **more efficient** than separate generation of electricity and heating/cooling
- Higher efficiency translates to lower operating costs (but requires capital investment)
- Higher efficiency **reduces emissions** of pollutants
- CHP can also increase **energy reliability** and enhance power quality
- On-site electric generation can **reduce grid congestion** and avoid distribution costs.



Critical Infrastructure and Resiliency Benefits of CHP

"Critical infrastructure" refers to those assets, systems, and networks that, if incapacitated, would have a substantial negative impact on national security, national economic security, or national public health and safety."

Patriot Act of 2001 Section 1016 (e)

Applications:

- Hospitals and healthcare centers
- Water / wastewater treatment plants
- Police, fire, and public safety
- Centers of refuge (often schools or universities)
- Military/National Security
- Food distribution facilities
- Telecom and data centers

CHP (<u>if properly configured</u>):


- Offers the opportunity to improve Critical Infrastructure (CI) resiliency
- Can continue to operate, providing uninterrupted supply of electricity and heating/cooling to the host facility



Emerging National Drivers for CHP

- Benefits of CHP recognized by policymakers
 - State Portfolio Standards (RPS, EEPS), Tax Incentives, Grants, standby rates, etc.
- Favorable outlook for natural gas supply and price in North America
- Opportunities created by environmental drivers
- Utilities finding economic value
- Energy resiliency and critical infrastructure

DOE / EPA CHP Report (8/2012)



http://www1.eere.energy.gov/manufacturing/distributede nergy/pdfs/chp_clean_energy_solution.pdf



CHP Today in the United States

U.S. CHP Installation Data

- **81.3 GW** of installed CHP at more than 4,400 industrial and commercial facilities
- 8% of U.S. Electric Generating Capacity; 14% of Manufacturing
- Avoids more than 1.8 quadrillion
 Btus of fuel consumption annually
- Avoids 241 million metric tons of CO₂ compared to separate production

CHP in U.S. WWTPs (CHP Capacity)


CHP Capacity	# of Systems
<50 kW	5
50-99 kW	15
100-249 kW	31
250-499 kW	33
500-1000 kW	39
>1000 kW	99
Total	222

CHP in U.S. WWTPs (Prime Mover)

Prime Mover	# of Systems
Reciprocating Engine	155
Microturbine	36
Combustion Turbine	15
Fuel Cell	10
Boiler/Steam Turbine	4
Combined Cycle	1
Organic Rankine Cycle	1
Total	222

Source: DOE CHP Installation Database (U.S. installations as of December 31, 2017)





DOE TAP CHP Screening Analysis

- High level assessment to determine if site shows potential for a CHP project
 - Qualitative Analysis
 - Energy Consumption & Costs
 - Estimated Energy Savings & Payback
 - CHP System Sizing
 - Quantitative Analysis
 - Understanding project
 drivers
 - Understanding site
 peculiarities

Annual Francisco Computer		
Annual Energy Consumption	Base Case	CHP Case
	Dase Case	CHr Case
Purchased Electricty, kWh	88,250,160	5,534,150
Generated Electricity, kWh	0	82,716,010
On-site Thermal, MMBtu	426,000	18,872
CHP Thermal, MMBtu	0	407,128
Boiler Fuel, MMBtu	532,500	23,590
CHP Fuel, MMBtu	0	969,845
Total Fuel, MMBtu	532,500	993,435
Annual Operating Costs		
Purchased Electricity, \$	\$7,060,013	\$1,104,460
Standby Power, \$	\$0	\$0
On-site Thermal Fuel, \$	\$3,195,000	\$141,539
CHP Fuel, \$	\$0	\$5,819,071
Incremental O&M, \$	<u>\$0</u>	\$744,444
Total Operating Costs, \$	\$10,255,013	\$7,809,514
Simple Payback		
Annual Operating Savings, \$		\$2,445,499
Total Installed Costs, \$/kW		\$1,400
Total Installed Costs, \$/k		\$12,990,000
Simple Payback, Years		5.3
Operating Costs to Generate		
Fuel Costs, \$/kWh		\$0.070
Thermal Credit, \$/kWh		(\$0.037)
Incremental O&M, \$/kWh		<u>\$0.009</u>
Total Operating Costs to Generate, \$/kWh		\$0.042



Example Screening Questions

• Do you pay more than \$.06/kWh on average for electricity (including generation, transmission and distribution)?



- Are you concerned about the impact of current or future energy costs on your operations?
- Are you concerned about power reliability? What if the power goes out for 5 minutes... for 1 hour?
- Does your facility operate for more than 3,000 hours per year?
- Do you have thermal loads throughout the year? (including steam, hot water, chilled water, hot air, etc.)
- Does your facility have an existing central plant?
- Do you expect to replace, upgrade, or retrofit central plant equipment within the next 3-5 years?
- Do you anticipate a facility expansion or new construction project within the next 3-5 years?
- Have you already implemented energy efficiency measures and still have high energy costs?
- Are you interested in reducing your facility's impact on the environment?
- Do you have access to on-site or nearby biomass resources? (i.e., landfill gas, farm manure, food processing waste, etc.)



Partnering with Local Utility



Albert Lea Wastewater Treatment Facility Albert Lea, MN

Application/Industry: Wastewater Treatment

Capacity: 120 kW (4 x 30 kW)

Prime Mover: Microturbines

Fuel Type: Biogas

Thermal Use: Heat for the digestion process, building heat

Installation Year: 2004



30 kW Capstone microturbines

Testimonials: "It gives us the ability to use the methane gas already generated at the plant. We are able to take a waste product and use if for something beneficial." – Steve Jahnke, City Engineer

"We are impressed with the effectiveness of the technology, and hope to encourage other Minnesota cities to consider capturing methane biogas to not only protect Minnesota's environment, but to save energy. The possibilities of the turbines don't end with energy production; they could also bring new businesses, and businesses are looking for cities that have vision." - Lois Mack, Minnesota Department of

Commerce



Opportunity Fuels


Lima Wastewater Treatment Plant

Lima, OH

Application/Industry: Wastewater Treatment Capacity (MW): 130 kW Prime Mover: Microturbines Fuel Type: Biomass Thermal Use: Heat for the Digestion Process Installation Year: 2012

Highlights: The CHP project was determined to provide:

- Best avenue for reductions of V.O.C.'s
- Best return of electrical energy
- Best capture of the heat for use in the WWTP





Source: http://www.puco.ohio.gov/puco/index.cfm/industry-information/industry-topics/combinedheat-and-power-in-ohio/chp-case-studies-voices-of-experience-workshop-june-20-2012/#sthash.MRLZAQNR.dpbs http://gemenergycapstone.com/wp-content/uploads/chp-ohio-casestudies-120913.pdf

Targeting Energy Neutrality

Glenbard Wastewater Authority

Glen Ellyn, Illinois

Application/Industry: Wastewater Treatment Capacity (MW): 750 kW (2 x 375 kW) Prime Mover: Reciprocating Engines Fuel Type: Biogas & Natural Gas Thermal Use: Heating Digesters Installation Years: 2016

Testimony: "The CHP project provides our wastewater facility a significant increase in operational reliability and resiliency. The CHP system is capable of operating on either biogas from our digesters or natural gas supplied by our local utility. Electricity for the facility is provided by the CHP system with backup provided by the local electric utility, and the heat required by the digesters is supplied by the free recovered thermal energy from the CHP system with backup, if required from the 2 existing dual fueled boilers" – Matt Streicher – Executive Director, Glenbard Wastewater Authority







Targeting Net-Zero

Downers Grove Sanitary District

Downers Grove, IL

Application/Industry: Wastewater Treatment



Capacity (MW): 655 kW Prime Mover: Reciprocating Engines Fuel Type: Biomass Thermal Use: Heat for Digestion Process Installation Year: 2014, 2017

Highlights: In 2014, DGSG installed a 280 kW engine-driven generator with heat recovery, along with a gas conditioning system. The plant began processing waste grease from nearby restaurants within the digester system to increase gas production. To fully utilize this resource, it installed an additional 375 kW engine and generator in 2017 with incentives from utility ratepayer Energy Efficiency Portfolio Funds.






nical Assistance Partnerships

US DOE Industrial Assessment Centers

- Established by the U.S.
 Department of Energy in 1976
- Teams of universitybased faculty and student engineers (trained 3,300+ students)
- Provide no-cost energy, productivity, and waste assessments
- Serve small and medium sized US manufacturers and wastewater treatment plants nationwide



The IAC program has already conducted over 18,362 assessments with more than 139,105 associated recommendations. Average recommended yearly savings is \$136,531.



DOE IAC Assessment Eligibility and Recent UIC IAC Assessments for WWTPs

- Located < 150 miles of a participating university
- Industrial facilities...
 - Within SIC Codes 2000-3999
 - Gross annual sales < \$100 million
 - < 500 employees at the plant site</p>
 - Annual energy bills between \$100K and \$2.5M
- Water and wastewater treatment facilities...
 - Water treatment plant >5 MGD
 - Wastewater treatment plant >2 MGD
 - Annual energy bills between \$250K and \$2.5M



Assessment Outcomes of UIC's Recent WWTP Energy Assessments in Illinois and Michigan

Annual Energy Costs	Recommen- dations	Identified Savings	Implemented Savings	Implemented Savings % of Energy Costs
\$464,279	3	\$52,498	\$52,498	11.3%
\$364,435	4	\$113,916	\$105,484	28.9%
\$345,255	6	\$226,157	\$216,698	62.8%
\$1,545,472	5	\$139,874	\$84,038	5.4%
	Costs \$464,279 \$364,435 \$345,255	Costs dations \$464,279 3 \$364,435 4 \$345,255 6	CostsdationsSavings\$464,2793\$52,498\$364,4354\$113,916\$345,2556\$226,157	CostsdationsSavingsSavings\$464,2793\$52,498\$52,498\$364,4354\$113,916\$105,484\$345,2556\$226,157\$216,698

MIDWEST

US DOE Better Buildings Sustainable Wastewater Infrastructure of the Future (SWIFt) Accelerator

- Established to catalyze the adoption of innovative and best-practice approaches in data management, technologies, and financing for infrastructure improvement within WWTPs
- 27 state, regional, and local organizations, representing 90+ WTTPs have joined the accelerator program
- Program partners seek to improve the energy efficiency at WWTPs by at least 30% and integrate at least one (1) resource recovery measure
- Program partners participate in peer exchanges and technical assistance forums about tools, approaches, technologies, and options
- DOE published the "Energy Data Management Manual for the Wastewater Treatment Sector" December 2017 https://www.energy.gov/sites/prod/files/2018/01/f46/WastewaterTreatmentDataGuide Final 0118.pdf



Pre-2015 Illinois Biogas-to-Energy Programs

- Illinois Biomass and Biogas-to-Energy Grant Program (2005-2015)
 - Funding was available through a renewable energy resources fund
 - Target projects were biogas or biomass fueled systems that produce electricity with CHP through gasification, co-firing, or anaerobic digestion
 - Technical assistance was available to assist grant applicants
 - Funding Structure (up to 50% of cost):
 - Biogas and Biomass Feasibility Study- \$2,500
 - Biogas to Energy Systems- \$225,000
 - Biomass to Energy Systems- \$500,000
 - CHP Projects Installed in WWTPs: Danville Sanitary District, Downers Grove Sanitary District, Northwest Regional Water Reclamation Facility
- Illinois Clean Energy Community Foundation Biogas Conditioning Grant
 - Funding was available to offset the costs of the equipment/technologies used to treat biogas conditioning
 - Up to \$250,000 per project

DCEO Energy Efficiency Programs Available for Wastewater Treatment Plants (2012-2017)

- Illinois Energy Now Energy Efficiency Program (2012-2017)
 - Wastewater Treatment Plants were identified as a target sector in 2012
 - Collaboration with individual treatment plants and trade associations was important
 - Technical assistance was available to assist applicants
 - Increased incentives were available for aeration specific equipment (20% min. savings, \$0.36/kWh)
 - Initial technology promoted was turboblowers for small-to-medium sized WWTPs
 - Other technologies later included: ultrafine diffusers, advance DO controls, controls related to aeration, ultra-violet for disinfection, twin screw compressors, etc.
- Illinois Public Sector CHP Pilot Program (2014-2017)
 - CHP became an eligible energy efficiency technology in State of Illinois in 2013
 - CHP was listed in the Illinois Technical Reference Manual (TRM) in 2014
 - 3 Level CHP Incentive for Design, Construction, and Production
 - Technical assistance was available to assist applicants
 - 17 applications submitted, including 7 CHP projects in WWTPs
 - 3 WWTPs received funding: Danville Sanitary District, Downers Grove Sanitary District, Glenbard Wastewater Authority



ComEd Energy Efficiency Programs Targeting Wastewater Treatment Plants (2017-TBD)

- ComEd identified the wastewater treatment sector as a key public sector target market
- Technical assistance is available for feasibility assessments and more detailed analyses
- Standard energy efficiency incentives are available (\$0.07/kWh)
- Increased energy efficiency incentives are available towards <u>aeration upgrades (</u>\$0.21/kWh)
 - e.g. turboblowers, high efficient blowers, fine bubble diffusers, dissolved oxygen controls, VFDs on blowers, etc.



Resources Available for Illinois Wastewater Treatment Plants through Illinois EPA

- Free Energy Assessments
 - Illinois EPA is offering free energy assessments to help local municipalities reduce the cost of wastewater treatment
 - Implemented through the Illinois Sustainable Technology Center (ISTC) and Smart Energy Design Assistance Center (SEDAC)
- Illinois EPA Revolving Load Fund
 - July 1, 2018 through June 30, 2019
 - Wastewater Loan Interest Rate = 1.84%
 - Drinking Water Loan Interest Rate = 1.84%



Summary and Next Steps

- CHP is a proven concept in WWTPs providing energy savings, reduced emissions, and opportunities for resiliency
- Emerging drivers are creating new opportunities to evaluate CHP today
- Resources are available regionally and at state levels to assist in developing CHP projects and assessing energy efficiency opportunities
- Contact the US DOE Midwest CHP TAP to perform a CHP Qualification Screening and/or receive other Technical Assistance



Thank You

Contact Information:

Cliff Haefke Director (312) 355-3476 chaefk1@uic.edu Graeme Miller Assistant Director (312) 996-3711 gmille7@uic.edu

U.S. DEPARTMENT OF ENERGY CHP Technical Assistance Partnerships

MIDWEST

www.MidwestCHPTAP.org

Best Practices in Improving the Efficiency and Resiliency of Water Treatment and Conveyance Systems

Examining Data From 583 Resource Recovery Facilities Across Wisconsin Megan Levy

> NGA Minnesota Water-Energy Nexus In-State Retreat August 3, 2018



Wisconsin Office of Energy Innovation

Presentation Overview

- Why Address Energy Use Through The CMAR
- Training Initiative
- Best Practice Guide Forecasted Energy Use
- What Does The Collected Data Look Like
- Process Questions
- Facility Distribution
- What is The Data Telling Us
- Summary Actions Q & A



Why Address Energy Use Through the CMAR?

One of the primary purposes of the CMAR is to foster **communication**.

Communication of Wastewater Resource Recovery Facilities needs among **operators**, governing bodies, and the **DNR**.

This project allows the CMAR to become an educational tool that increases awareness of the importance and **value** of wastewater treatment **energy efficiency.**




Why Address Energy Use Through the CMAR?

The Clean Water Loan Fund requires an Energy Audit, first step of energy audit is to create an energy use baseline.

In 2017 Focus on Energy provided energy efficiency incentives to over 50 Wisconsin Wastewater Treatment Facilities.

FOCUS on WASTEWATER





Wisconsin Office of Energy Innovation

Collaborative Process to Develop Questions

Design Phase (2015)

CMAR Energy External Workgroup with in-person meetings to develop the new questions and data table with the charge of keeping it short, simple and easy to complete.

Jack Saltes – DNR Madison Joe Cantwell, Focus On Energy Jeremy Cramer, Fond du Lac WWTP Kevin Freber, Watertown WWTP Sharon Thieszen, Sheboygan WWTP Gary Hanson, Short Elliot Hendricksen Steve Ohm, DNR-Rhinelander David Argall, DNR-Madison Megan Levy, OEI Kevin Splain, OEI





137

Initial Questions on Energy Use/ Training Initiative

Committee determined that questions should be separated into "inside the fence" and "outside the fence"


WDNR, OEI, Focus held training sessions in all DNR regions. Great attendance, good questions, lots of important input.

Jack Saltes Farewell Tour



Wisconsin Office of Energy Innovation

Facility Distribution Across the State



What the Data Looks Like and What it Tells Us-2016

Flow Range (MGD)	Number of Facilities	Median Flow (MGD)	Best Quad (kWh/MG)	Median (kWh/MG)	Lowest Quad (kWh/MG)
0 - 0.05	163	0.023	123.33	3,825.65	9,089.09
0.05 - 0.125	117	0.072	1,542.22	4,253.15	6,357.29
0.125 - 0.25	79	0.184	2,677.83	3,894.32	5,523.13
0.25 - 0.5	70	0.352	2,290.91	3,607.38	4,564.06
0.5 - 1	39	0.644	1,921.98	2,781.67	3,207.98
1 - 5	58	1.630	1,702.18	2,058.50	2,906.92
>5	19	10.986	1,351.18	1,965.30	2,487.36
0-100	545	0.118	1,575.52	3,237.91	5,663.82



Wisconsin Office of Energy Innovation

What the Data Looks Like and What it Tells Us-2017

Flow Range (MGD)	Number of Facilities	Median Flow (MGD)	Best Quad (kWh/MG)	Median (kWh/MG)	Lowest Quad (kWh/MG)
0 - 0.05	186	0.022	11.83	3,855.82	8,941.33
0.05 - 0.125	125	0.074	1,279.16	4,607.23	6,525.83
0.125 - 0.25	81	0.187	2,516.79	3,690.82	5,563.75
0.25 - 0.5	73	0.340	2,403.38	3,271.55	4,228.38
0.5 - 1	41	0.652	2,175.83	2,609.37	3,502.66
1 - 5	58	1.694	1,660.88	2,172.53	2,884.26
>5	19	10.981	1,453.91	1,894.51	2,523.28
0-100	583	0.100	1,538.74	3,072.32	5,392.48



Wisconsin Office of Energy Innovation

What the Data Looks Like and What it Tells Us

	2016	kWh/B	OD		
Flow Range (MGD)	Number of Facilities	Median Electricity Consumed (kWh)	Best Quad (kWh/BOD)	Median (kWh/BOD)	Lowest Quad (kWh/BOD)
0 - 0.05	163	33,004	95.54	2,761.99	5,723.26
0.05 - 0.125	117	118,680	1,253.23	2,701.51	4,230.17
0.125 - 0.25	79	263,920	2,056.31	2,838.25	3,925.73
0.25 - 0.5	70	425,140	1,489.41	1,904.17	2,715.07
0.5 - 1	39	639,606	995.86	1,422.73	2,063.95
1 - 5	58	1,495,596	826.82	1,057.86	1,400.75
>5	19	6,524,275	675.56	1,101.78	1,278.79
0-100	545	168,200	987.59	2,062.65	3,859.35



Wisconsin Office of Energy Innovation

142

What the Data Looks Like and What it Tells Us

	2017	kWh/BC	D		
		Median			
Flow Range	Number of	Electricity	Best Quad	Median	Lowest Quad
(MGD)	Facilities	Consumed	(kWh/BOD)	(kWh/BOD)	(kWh/BOD)
		(kWh)			
0 - 0.05	186	29,420	8.40	2,370.80	5,463.86
0.05 - 0.125	125	112,600	1,365.37	2,958.71	4,349.39
0.125 - 0.25	81	224,830	2,010.55	2,737.36	3,628.20
0.25 - 0.5	73	415,680	1,508.91	1,863.72	2,571.02
0.5 - 1	41	736,825	992.27	1,697.89	2,178.98
1-5	58	1,527,130	810.50	1,096.39	1,537.67
>5	19	6,734,757	683.79	1,032.74	1,504.45
0-100	583	163,700	920.54	2,035.78	3,617.16




Wisconsin Office of Energy Innovation

Process Questions

7.2 Energy Related Processes and Equipment 7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply): Aerobic Digestion Anaerobic Digestion Biological Phosphorus Removal Coarse Bubble Diffusers Dissolved O2 Monitoring and Aeration Control Effluent Pumping Fine Bubble Diffusers Mechanical Sludge Processing Nitrification SCADA System UV Disinfection Variable Speed Drives Other:



Facility Performance and Benchmarking Analysis



Water and/or wastewater utility managers index their facility's energy usage through a production or demand index, such as kWh/MGD or kWh per 1,000lb of Biological Oxygen Demand (BOD). This index is called a Key Performance Index (KPI) or Energy Performance Index (EPI). Establishing an energy baseline helps facility managers understand the relative efficiency or change in efficiency relative to the core purpose of the operation, i.e., water production or wastewater treatment. It is recommended utilities set a goal to save five to ten percent of its energy after it has implemented energy efficiency measures, a new annual average line is set as the targeted KPI level with monthly Monitoring & Verification (M&V).




Water Utility Analysis

Quartile Statistical Benchmarks where 1 = Top Quadrant 25% Best, 2 = 2nd Quadrant Good, 3 = 3rd Quartile below Median & 4 = 4th Quadrant Bottom 25% Poorest

Utility ID	Utility	Performance Benchmark	2010	2011	2012	2013	2014	2015	2016	2017	2010-2017 Average
3740	Mineral Point Mun Water Utility	kwh/1000 Gal Quad	4	3	3	3	3	3	3	3	3
3740	Mineral Point Mun Water Utility	% Water Losses Quad	4	4	4	4	4	4	4	4	4
3740	Mineral Point Mun Water Utility	\$ per kwh Pumping Quad	1	1	1	1	1	1	1	1	1
3740	Mineral Point Mun Water Utility	\$ per 1000 Gallons Quad	2	3	3	2	2	2	3	2	2

Water utilities with benchmarks of 3 (Yellow) and 4 (Red) can request that MEETAP prepare a system analysis of wells, towers and pumps to estimate demand, energy and cost savings (capacity and average operating characteristics – on-peak, capacity factor, constant flow high pressure control vs variable flow constant pressure, etc.).

Utility ID	Utility	Performance Benchmark	2010	2011	2012	2013	2014	2015	2016	2017	2010-2017 Average
3740	Mineral Point Mun Water Utility	kwh/1000 Gallons	2.89	2.67	2.80	2.58	2.72	2.97	2.62	2.76	2.75
3740	Mineral Point Mun Water Utility	% Water Losses	34.07%	41.39%	31.15%	43.07%	47.78%	34.77%	34.66%	38.55%	38.18%
3740	Mineral Point Mun Water Utility	\$ per kwh Pumping	\$ 0.08	\$ 0.10	\$ 0.09	\$ 0.09	\$ 0.07	\$ 0.09	\$ 0.11	\$ 0.10	\$ 0.09
3740	Mineral Point Mun Water Utility	\$ per 1000 Gallons	\$ 0.23	\$ 0.26	\$ 0.26	\$ 0.24	\$ 0.20	\$ 0.28	\$ 0.30	\$ 0.28	\$ 0.26





Top 25 Low Cost No Cost Measures to Implement




https://focusonenergy.com/business/WWbridge



Wisconsin Office of Energy Innovation

2017 Energy Advisor Territory Map





Wisconsin Office of Energy Innovation

Partnerships Create More Resources

- Focus on Energy 800.762.7077
 - <u>https://focusonenergy.com/business/water-wastewater</u>
 - Energy Advisor Map, <u>focusonenergy.com/ea-map</u>
 - Ag, Schools, and Government Program
 - Large Energy User Program
- Office of Energy Innovation
- <u>Wisconsin Municipal Energy Efficiency Technical Assistance</u> <u>Program (MEETAP)</u>
- Request Wastewater Treatment Facility Energy Tracking Tool: <u>Vanessa.Durant@Wisconsin.gov</u>
- DNR Clean Water Loan Fund- eliminate PF caps, and determine list of priorities for PF Incentive program:
 - Regionalization
 - P reduction
 - ENERGY EFFICIENCY!!!!!!!




Summary

- Range of reported energy use: 690 to 26,926 kWh/MG
- Per Cent of Energy Reduction Available (From Average to 75 %'ile Data): 24 to 50 %
- Amount of forecasted energy savings available from wastewater facilities: 256 MWh/year
- Forecasted value of energy savings at \$0.10 /kWh
 256,000,000 kWh X 0.10 \$/kWh = \$25,600,000 / year
- DNR CWLF will provide matching funds in the form of principal Forgiveness to municipalities working with Focus on Energy
- More data sharing = better incentives for Municipalities



Wisconsin Office of Energy Innovation

Take Away & Actions





151

151

Take Away & Actions

TAKE AWAY

- Wastewater System energy use can be significantly reduced
- Focus on Energy assistance is available
- If a facility has completed one energy project now look for the second, third, fourth
- ACTIONS
 - Continue data analysis
 - Reach out to facilities with high energy use
 - Develop and provide additional education and training materials and/or sessions
- Encourage facilities to contact Focus on Energy for assistance Provide individual reports to WWTFs that show blind comparisons



152

Questions – Comments - Contact



NATIONAL GOVERNORS ASSOCIATION



Energy Efficiency & Renewable Energy




Energy Savings Performance Contracting For the Wastewater Sector

Alice G. Dasek

Office of Weatherization & Intergovernmental Programs U.S. Department of Energy August 3, 2018

Introduction

- Released in March 2018
- Explores how ESPC can help facilities achieve priorities for the wastewater market
- One of a series of guides for markets underserved by ESPC









- What is Energy Savings Performance Contracting (ESPC)?
- Why ESPC?
- A Look at the ESPC Market
- ESPC Wastewater Case Studies
- DOE Resources for the Wastewater Sector





What is ESPC?



Definition


ESPC is

A contracting and financing method that provides upfront financing for energy efficiency projects and repaid by the savings on utility bills resulting from the upgrades





How Does it Work in Practice?










160


ESPC Relationships







Financing Options







The Performance Guarantee

Unique feature of ESPC

The ESCO:

- Assumes financial, operating, and performance risk
- Guarantees project savings
- Measures and verifies savings
- Provides reimbursement if guaranteed savings not met and/or fixes the problem at no additional cost







Why ESPC?

General ESPC Benefits

- No upfront costs needed
- ESCO accountable for project design, construction, and post-installation monitoring
- ESCO serves as single point of contact for project
- ESCO takes on project risks
- Guaranteed cost and energy savings
- Savings measured and verified as "real"





Opportunities for Wastewater Facilities

- Achieve Wastewater Sector Mission
- Upgrade Infrastructure
- Manage Energy Costs





Achieve Wastewater Sector Mission

Issue

- Increasingly stringent regulatory requirements
- Demand on facilities expected to grow 23% by 2032¹
- Need for reliable service for customers through outages

Opportunity

- ESPC project upgrades can help plants meet NPDES discharge permit requirements
- Streamlined operations help meet the demand for clean water at reasonable user rates
- Generating energy onsite can support operations resiliency





Upgrade Infrastructure

Issue

- WRRFs built to meet supply, not efficiency
- Aging equipment costs more to operate & maintain
- Infrastructure rated a D+ and capital investment needs estimated at \$271B¹ (\$2.4B over next 20 years in MN²)

Opportunity

- Comprehensive nature of ESPC projects allows upgrades that improve overall project operations
- Upgrades can ensure operational stability
- ESPC projects can provide upfront investment not readily available





Manage Energy Costs

Issue

- 2000-2010 energy costs rose by ~80%³ and are estimated to continue rising through 2040⁴
- Energy often second highest operating cost in WRRF
- WRRFs represent 30-40% of energy use in community

Opportunity

- Individual ESPC projects have demonstrated up to 50% energy savings
- ESPC project can reduce utility bills
- Equipment improvements can also reduce other operating & maintenance costs



³ "Annual Energy Review 2011." (2012). US Energy Information Administration. DOE/EIA-0384(2011). September 2012. Page 72. http://www.eia.gov/totalenergy/data/annual/pdf/aer.pdf
 ⁴ "Annual Energy Outlook 2013." (2013). US Energy Information Administration. DOE/EIA-0383(2013). April 2013. Page 97-98. http://www.eia.gov/outlooks/archive/aeo13/



A Look at the ESPC Market



A Perfect Storm for ESPC

- Tight budgets for energy efficiency retrofits
- Good energy savings track record



- ESPC projects active in 2012 saved 34 million TWh and 224 million MMBtu or approximately 1% of total US commercial building energy consumption⁶
- A typical ESPC project in the MUSH market saves approximately 13% to 31% annually compared to its baseline consumption⁷
- High market growth potential for ESPC
 - Anticipated 2017 revenues of \$7.6 billion, representing an average annual growth of 13% over the period 2015-2017⁸
 - Estimated ESPC project investment opportunity in MUSH market: ~\$51.8-\$86.8 billion⁹



⁶ LBNL, 2015. "Estimating Customer Electricity and Fuel Savings From Projects Installed by the US ESCO Industry."
 ⁷ LBNL/NAESCO database of ESCO projects



The Potential for ESPC in WRRFs

Market	2008 (n=29)	2011 (n=35)	2014 (n=43)		
Federal Govt.	15.4%	21.4%	20.7%		
State/Local Govt.	23.0%	24.0%	25.4%		
K–12 Schools	22.4%	19.4%	23.5%		
Univ./College	16.2%	13.7%	10.0%		
Healthcare	6.3%	5.9%	5.9%		
Housing/Other	9.4%	7.5%	6.6%		
Commercial/Industrial	7.3%	8.1%	7.9%		
TOTAL	100.0%	100.0%	100.0%		

Source: "U.S. Energy Service Company Industry: Recent Market Trends." by Elizabeth Stuart, Peter H. Larsen, Juan Pablo Carvallo, Charles A. Goldman, and Donald Gilligan. October 2016. Appendix A. Page 48.

- State/local governments incur approximately 95% of the capital investments annually to maintain & improve the infrastructure
- ESPC can provide upfront project financing in the face of limited budgets
- Upgrades in WRRFs can achieve up to 50% energy savings





172

Bettei

Note Regarding ESPC Legislation

- Most states have legislation enabling ESPC
- Individual states might have language addressing ESPC specifically for school districts
- Legislation may set requirements for procurement, allowable energy conservation measures, financing terms, structure of the guarantee, M&V, and budget streams
- Good practice to consult your General Counsel, the State Energy Office, and/or project facilitator





173

What's Holding Back the ESPC Market

Frequent barriers to broad use of ESPC expressed by **MUSH** market:

- Complicated and time-consuming procurement process
- Hard-to-access data on existing projects
- Inadequate data to make business case for ESPC
- Insufficient knowledge about mechanism details
- Inexperience in using ESPC in certain market sectors







ESPC Case Studies for Wastewater Facilities



City of Rome, NY

- Small city population 35,000
- Faced state and local budget cuts, shrinking tax base
- Goals of stable infrastructure, financial viability, water production quality, and economic development
- \$6.6 million in energy improvements
 - Fine-bubble aeration system
 - Low-Lift Pumps with Variable Frequency Drives (VFDs)
 - Dissolved Oxygen (DO) controls
 - New cleaning schedules allowed for total summer shutdown
- Post-project can process greater volumes and more easily meet NPDES requirements
- \$100,000+ annual savings







City of Riverbank, CA

- Small city population 23,000
- Focus on infrastructure stability and product quality
- \$3.9 million in energy improvements
 - Upgraded to fine-bubble aeration system
 - Variable Frequency Drives (VFDs)
 - Filters, valves, gauges, control panels
- \$200,000 annual savings





Hutchinson Wastewater Facility, MN

- Small city population 14,000
- Capacity 3.5 MGD/day
- Focus on infrastructure stability



- \$375,000 in energy improvements
 - Variable Frequency Drives (VFDs)
 - Lighting
 - Reduced maintenance needs
- Post-project motors can run at 30-35% capacity
- \$60,000 annual savings (almost twice the guarantee)



178



DOE Resources for Wastewater Facilities



ESPC Accelerator Toolkit

https://betterbuildingssolutioncenter.energy.gov/ene rgy-savings-performance-contracting-espc-toolkit

- The ESPC project process
 - Model contract documents, ESPC project database, financing decision tree, online guide to implementing ESPC, best practices for selecting energy service company
- The ESPC institutional infrastructure
 - Resources for developing ESPC project champions and for building support network for ESPC across jurisdiction, fact sheet on economic impact analysis tools, ESPC vs. Design-Bid-Build, guide for establishing ESPC technical assistance program
- Application of ESPC to new markets
 - Guide to ESPC in the wastewater sector





DOE Resources for Wastewater

- Better Plants
- Superior Energy Performance (SEP) Program
- ISO 50 001 Ready
- Industrial Assessment Centers (IACs)
- CHP Deployment Program
- CHP Technical Assistance Partnerships (CHP TAPs)
- CHP for Resiliency Accelerator
- Sustainable Wastewater Infrastructure of the Future (SWIFt) Accelerator





SWIFt Goals & Structure

Goals

- Document model plans for transitioning to a sustainable infrastructure that will help drive more solutions in the industry
- Develop assessment and decision tools for selecting best-practice approaches and tools on the pathway toward a sustainable infrastructure

Structure

182

- Phase 1: Energy Data Management
- Phase 2: Measure Planning & Implementation
- Phase 3: Project Financing
- Phase 4: Plan Drafting



Energy Data Management Resources

- Published 2017
- Explains the energy data management process, provides step-by-step approach, and provides data tool comparison matrix

Better Buildings	Tool interface and entering data	# of Months of data needed	Data needed to use the tool	What metrics does the tool calculate?	Internet needed?	Facility size/type requirements	Other features of the tool	Technical assistance available for the tool	Compatibility with other data tracking tool(s)?
Portfolio Manager - EPA http://portfoliomanager energyst ar.gov/pm/signup	Online tool to measure and track energy and water consumption and greenhouse gas emissions. Upload from Excel or enter data manually	24 months	1) Property information (sq. ft.) 2) Monthly energy data (WAR, therms) 3) Monthly how data (god, MSO) 4) Plant annual average or influent and effuent BOD (mg/) 5) Plant design flow rate (MSO) 6) Plant features-trickle filter, nutrient removal, onsite generation	Energy use intensity per flow (kBtu/MGD) Greenhouse gas emission intensity (kg CO2e/gpd) Avoided GHG emissions	Yes	All types/sizes, but ENERGY STAR score only for facilities > 0.6 mgd	- Con be used to manage different property types [e.g., building:] within the same portfolio. - Data request templates can be used to request data from multiple facilities - Vestner-normalised values based on Bo-year everage temperature - Nutrint removal indicated as - Nutrint removal indicated as STAR score	Online Resources	Compatible with most tools
Energy Assessment Tool (EAT) - EPA Region 4 ttps://www3.epa.gov/region9/wa terinfrastructure/audit.html	Downloadable Excel- based tool to assess individual baseline energy use and costs through utility bill and equipment analysis		1) Date & monthly flow (DMR data) 2) KWh monthly usage and monthly costs (KW demand optional) 3) Monthly gas usage and bill ccf or therms/ \$	• KWH/MG • Cost/MG • KWh/ MG treated	No	All types/ Small- medium sizes (up to 3 electric meters per facility)	 Accommodates biogas and solar Designed for 3 years; needs tweaking to accommodate longer timeframes 	Region 4 experts	PM and EnPi tool
iew Hampshire spreadsheet tool (not publicly available)	Customized by State of NH, this Excel spreadsheet-based tool requires manual entry of energy data.	24 months	1) Design flow (MGD) 2) Annual average daily flow (MGD) 3) Annual average energy usage (KWh) 4) Nutrient limit types 5) Annual average daily BOD removed	 kWh/ Ib BOD removed kWh/ MG treated 	No	All types/sizes	Suitable for both portfolio and individual facility use	N/A	Compatible with most tools
Energy Performance Indicator (EnPI) - DOE ttps://ecenter.ee.doe.gov/EM/to ols/Pages/EnPLaspx	Downloadable add-in for Excel. Upload dats from external spreadsheet or enter data manually through step-by-step wizard	24 months	1) Monthly or weekly energy consumption dats 2) Monthly or weekly production data (metric tons, million gallons of now, BOO, COO etc.) 3) Westher data - Heating Degree Days (HDDS), Cooling Degree Days (CDDs), humidaly, monthly rain average temperature, etc.	KWh/ Ib BOD removed KWh/ MG treated KOD mg/L Avoided GHG emissions	No	All types/sizes	Regression analysis (forecast, backast, and chaining) for improved accuracy - Can be used by both individual facilities and portfolios (corporate roli-up functionality) - Tool update Un-annually (optional download)	Online Resources	Compatible with most tools
Qualified Energy Savings Tool (QEST) Tool- DOE (Expected to be available Feb-	An online tool you can t	use to track and a	nalyze energy use and greenhouse ga:	emissions. Internet nee	ded. Standard reg	ression analysis vs.	customized as in EnPl.		





Energy Data Management Manual for the Wastewater Treatment Sector DECEMBER 2017



https://www.energy.gov/sites/prod/files/2018/01/f46/WastewaterTreatmentDataGuide_Final_0118.pdf

DOE/EE.1700



ENERGY

Low- and No-Cost Measures List



Sustainable Wastewater Infrastructure of the Future (SWIFt)

LOW- AND NO-COST MEASURES LIST

These measures were recommended by U.S. DOE Industrial Assessment Centers and implemented at various water resource recovery facilities, averaging <2 year payback periods.

 - -		 			
 	n.e	 -	-		
 U 1	25			-	

- Test, calibrate, and maintain dissolved oxygen level/sensors in aeration tank(s).¹
- Shift to smaller HP pumps/blowers during nightly low-flow periods or seasonal low-flow periods, if applicable.2
- Reduce blower pressure to the minimum required through proper maintenance of aeration diffusers and distribution system to minimize head loss. Control the set point in the aeration blower control strategy. Also, identify, assess and repair aeration system air main leaks - (replace gasket, repair corrosion, underground maintenance) and lower aeration tank levels to reduce air header static pressure, if applicable, (May need sensing O2 level).
- Turn off equipment when not in use (e.g., turn off aerobic digester blower periodically or operate intermittently).
- Adjust system operations when there is a change in wastewater load.
- Raise wet well levels to reduce static head in the pump system. Coordinate all control points (low-level alarm, pump start/stop, high-level alarm) to adjust the wet well level upward. Consider hydraulic profile of the facility when doing so.
- Eliminate leaks in inert gas and compressed air lines/valves.
- Operate select aeration tanks as needed while also establishing operating protocols to enable the plant to bring tanks back on line efficiently.
- Routinely clean UV lamp sleeves to enhance transfer efficiency and decrease the number of UV lamps where/when possible while still meeting disinfection needs.
- Idle aeration basins/zones, if not needed (periodic maintenance may still be needed).
- Reschedule plant operations or reduce load to avoid on-peak hours (e.g., operate dewatering equipment during off-peak, load digesters during off-peak, repair equipment, and shift recycling of supernatant to off-peak).

¹ Requires emptying tanks. Otherwise, payback can be much shorter. ²Must have more than sporadic (significantly frequent) nightly low-flow periods.

Assessment

- Review and assess ventilation requirements to optimize efficiency, reduce space conditioning during non-working hours, and manage space conditioning energy use during non-occupancy times.
- Assess the potential to remove organics prior to entering the secondary treatment system. Assess the capability for high strength organic dischargers to feed directly to an anaerobic digester.
- Review operations to identify any pumps or blowers that are being throttled and assess them to determine if they can be adjusted to operate more efficiently.
- Assess air and water piping systems in need of insulation (exposed piping).
- Identify equipment speeds and resheave blowers where needed.
- Consult your energy utility account manager to evaluate rate schedules and determine the most efficient rate for your facility.

Installation

- Install timers on light switches and occupancy sensors in little-used areas and adjust for scheduled operations as needed.
- Install programmable thermostats and use night set-back/setup settings.
- Turn off unnecessary lighting and install occupancy sensors.
- Identify and use energy-efficient belts compatible with your facility's equipment.
- Change aeration blower intake filters regularly to minimize air intake resistance.³
- Use automatic controls when available to optimize equipment, process monitoring, and operations.



^aUse static pressure to check if filters need replacement.



Measure Planning Workbooks

Better Buildings st: To bely a malemater terstanol famility determine if it about install and/or optimine blance tenboologies Saure Range [1 - laural/meral, 4 - bigheal/beal] [Range independent for each ariterina] المعا والمانية Preparatio Section Irabaalaas dista dise will (codeniine in maalki What is are aprealiant ---Ible arfile real mereleali and a second second bisher and poleolial mereleali He layers for las a far ller brarfil depend _____ 6.... premilled premilled a azrizbilila i premilled influent wale What is l ingent? parameter je.g., DOD je.g., 200 All class canal, lawer and goality and 11-Jean, BOD TSSI TSS, HH, J sisting seates ranala higher samer, and 4588K 4588K-4588K \$100K - \$200K pr lealegies al lle prise of (§188K pro blass depends as the estating Maure per blauer blauer LI..... galen annyaarala and Thetes analysi anfilware Ibr Inco Owned aber lara-di 4----Owneall ability equate blauer ereall blue Maureil, analyse large analyse large bisher same for the agales lar dama 1.1:1 ar daus 1.1:1 la Jean, 4:1 Li.e. daws 2:11s 2:1 1:1 leredeus is 4:1 [58X1-98X] IS \$1000 112.5X Iv edualization 125X 1. 58X 188X1.25X1 25X) jankey Palealist Dearfile +squing +prealises Criteri Requires facilityaperator la Relieum aled aperator la What Issue aide. Nigher nanings equals make freezes <18X 18 - 28 X 28 - 58X >382 -----minimal. higher same aper also - and all in arrded adjustments laraka fa ---i-galjan la cala والدونورية la aperat high create - ffeeline امت. متدامته eral eran Loure Irael a anala; aperalise; likal nan bi maintenance rdian les offerl equals reformed blamer. ileas la •6 plast higher ana ---maintain What will ra and Brir realise (r. be the Sharler paybank period Ibal sas be aras lias 7 - 18 gears anaples. >18 gears 3.7 dignary brariane. paghast equals higher source proprielar rformed **k**elurre ---l--l anala, periodi drals sgale plant ----elealeani Igginally 5 In ·····

Blauer Technologies + Optimization Market Landrcape DRAFT - FOR DISCUSSION ONL

- **Real-Time Monitoring & Control**
- **Energy Management Systems**
- Infiltration/Inflow Studies
- Ammonia-based Aeration Control (ABAC)



- **Dissolved Oxygen** (DO) Control
- **Blower Technologies** + Optimization
- **Emerging Diffuser Technologies**
- **Pumping System Technologies + Optimization**

Energy Assessments

SWIFt Measure Planning Workbook Instructions DRAFT - FOR DISCUSSION ONLY

The SWIFt Measure Planning Workbook is a tool to assist wastewater treatment facilities in evaluating multiple energy conservation and resource recovery measure proposals in a side-The following steps allow the user to assess a measure's overall range of performance, indicate the individualized importance of measure performance criteria, score multiple measure r performance criteria, and view overall measure proposal scores side by side. Ultimately, the user may include this workbook in a facility improvement plan as a useful resource that indi priorities and evaluates and recommends one or more measure proposals

Password Protection: The contents of all sheets in this workbook are locked for editing, with the exception of the gray cells the user should fill out to complete the workbook. To unlock a sl click the "Review" tab and then click "Unprotect Sheet

	Instructions
Dashboard	Once the user has completed the applicable number of Evaluation Matrix sheets, the Dashboard sheet will display the names, weighted scores, and too proposal evaluation (uploaded automatically), allowing the user to view a side-by-side comparison of each proposal based on its criteria performance. the arrows in the any of the gray column headings and select sorting/filter options to change the display of criteria, weights, and weighted scores. The scores displayed on the sheet cannot be changed directly on the Dashboard sheet, but will be changed based on weight adjustments in the Criteria We score adjustments in the Evaluation Matrix sheets.

Printing Instructions: This workbook is preset to print settings that will print all sheets on single, one-sided letter-sized (8.5" x 11") pages. If sheets are not printing in a satisfactory fashic print settings may be of assistance:

- 1. In Print > Settings, select "Print Active Sheets", or return to sheet, highlight selection for printing, and then select "Print Selection"
- 2. Select if sheets are printed on one side or on both sides of the page.

Better

Buildings[®]

- 3. In Orientation, select "Landscape Orientation" due to their layout, this orientation is recommended for all sheet: 4. In Page Size, select Letter (8.5" x 11") size or larger, including Tabloid (11" x 17").
- 5. In Margins, set to "Narrow Margins" or "Custom Margins", setting all sides to 0" and Center on Page Horizontally and Vertically

Instructions Market Landscape Criteria Weighting Evaluation Matrix 1 Evaluation Matrix 2 Evaluation Matrix 3



Measure Planning Workbooks contd.

	Technologies + Optimization Criteria Weighting DRAFT - FOR DISCUSSION ONLY stewater treatment facility determine priorities with regard to blower technologies + optimization lange (I = lowest/worst, 4 = highest/best) (Range independent for each criterion)									
Criteria	2	3	4	Scoring notes	Veight					
/hat is the purchase price of blower equipment?" \$300K - \$500K per blower		\$100K - \$300K per blower <\$100K per blower		All else equal, lower cost equals higher score, cost depends on the existing system components and control software	17%					
Ongoing Operations										
What level of effort is needed to operate and maintain blower technologies and their control system?*	Requires operator to make manual adjustments occasionally; Several regular maintenance items to maintain operation (e.g., bearings, seals, electronic components)	Relies on some operator tweaks for effective operation; medium level of maintenance that can be performed by plant personnel	Simplefautomated operation; minimal maintenance requirements that can be performed by plant personnel; mean time between overhauls typically 5 to 10 years	Lower level of effort equals higher score	17%					
Potential Benefits										
What facility-wide energy savings are expected?	10 - 20%	20 - 30%	>30%	Higher savings equals higher score	17%					
What will be the payback period?	7 - 10 years	3 - 7 years	<3 years	Shorter payback period equals higher score	17%					
Other										
				Total Veight:	100%					

Name:

- Anaerobic
 Digestion
- Combined Heat & Power (CHP)
- Heat Recovery
- Biosolids Energy Recovery

Better Buildings	Blower Technologies + Optimization Evaluation Matrix 1 DRAFT - FOR DISCUSSION ONLY Goal: To help a wastewater treatment facility determine if it should install and/or optimize blower technologies Score Range (1 = lowest/worst, 4 = highest/best) (Range independent for each criterion)									
Criteria	1	2	3	4	Scoring notes	Veight	Score	Veighted Score		
What level of effort is needed to operate and maintain blower technologies and their control system?*	Requires operator to make frequent manual adjustments; high repair costs; professional maintenance necessary; complex proprietary controls system requiring expert contractor support	Requires operator to make manual adjustments occasionally; Several regular maintenance items to maintain operation (e.g., bearings, seals, electronic components)	Relies on some operator tweaks for effective operation; medium level of maintenance that can be performed by plant personnel	Simple/automated operation; minimal maintenance requirements that can be performed by plant personnel; mean time between overhauls typically 5 to 10 years	Lower level of effort equals higher score	17%				
Potential Benefits										
What facility-wide energy savings are expected?	<10%	10 - 20%	20 - 30%	>30%	Higher savings equals higher score	17%				
What will be the payback period?	>10 years	7 - 10 years	3 - 7 years	<3 years	Shorter payback period equals higher score	17%				
Other										
								<u> </u>		
								1		



Total Veight: 100% Total Score:

U.S. DEPARTMENT OF

Thank You!

Questions?

For additional information, contact

Alice Dasek alice.dasek@ee.doe.gov






187

WORKFORCE DEVELOPMENT

Minnesota Water-Energy Nexus In-State Retreat







David Kuzminski, Coordinator

Water and People Program/Water Boot Camp



BACKGROUND

 Experts predict that water industry in general will be experiencing a 40% "brain drain" within the next five years.

 State of Connecticut has 1,020 certified distribution & treatment operators, 40% or 432 will be eligible to retire in 5 years.

CTAWWA'S RESPONSE

- Process began 9 years ago
- Initial Meeting CTAWWA & Superintendent of Portland, CT schools
- Previous CTAWWA working relationship with Town Tech Education Partnership Program - program developed in early 1990s that gives high school students real life projects in partnership with town government.

THE PROCESS BEGINS

 Presentation then made to the Portland Board of Education proposing a new course focusing on careers in the water industry. Board feedback positive; requested more information

 CTAWWA education committee partners with the Town of Portland Town Tech Educational Partnership Program, Portland High School, Gateway Community College and State of CT DPH to develop a high school curriculum that brings awareness to careers with the water industry.

GOAL AND INNOVATION

 Goal - offer the class to juniors & seniors with end result being students eligible to sit for the State of Connecticut operator in training exam or continue on the Gateway curriculum with advanced credits. At the very least we will bring exposure to careers the water industry to our high school student population.

Concept innovation – first of its kind offered at public high school level

"WATER AND PEOPLE" CLASS IS BORN!

- Curriculum designed to satisfy requirements to meet the Small Systems
 Operator in Training exam as well has meet State Board of Education new
 course requirements. At the completion of the course, senior students will be
 eligible to sit for the Operator in Training exam.
- Course consists of class training and labs. Lab schedule includes topics such as Total Coliform, Filtration, Chlorination, Pressure, Flow Rate, Cross Connections, Water Quality, Meter Testing and Operator Safety and field trips.

"WATER AND PEOPLE" CLASS IS BORN!

 Advanced placement credits toward the Water Management Program offered at Gateway Community College in North Haven, CT

 Partnering between all state agencies along with all the educational institutions has been critical

FUNDING FOR "WATER AND PEOPLE"

 Town of Portland notified section that \$7,500 would be required to start program.

 CTAWWA will fund the first year of the program, continue to play major continuing role in success and sustainability of the program, and develop outside funding on the State and Federal levels for sustainability of this important course beyond the immediate school year.

MOU – PORTLAND AND CTAWWA

<u>Terms of Funding</u>

 CTAWWA wants this course to be a model for similar courses in Connecticut and around the country. The curriculum will need to be shared with other public school systems to help the water industry deal with looming workforce issues.

Memorandum of Understanding

Agreement signed that the Portland High School "Water and People" curriculum will be shared with other school systems, at no charge, upon written request.

THE GOOD NEWS!

 67 students have gone through the course to start January 2009 at Portland High School

 Co-teachers including CTAWWA's Dave Kuzminski, have taken DPH course in Water Treatment for Operators and are "tweaking curriculum". Eighteen labs arranged.

CTAWWA will give each graduate a one year student membership in AWWA.

WATER AND PEOPLE GOES TO BLOOMFIELD HIGH SCHOOL



Water & People - Now in Bloomfield

Click for Complete Gallery



AWARDS

2010

EPA Environmental Merit Award

Joint Educational Public Health Drinking Water Merit Award


2014











Thank You!

NATIONAL GOVERNORS ASSOCIATION



Roundtable Discussion

Facilitator: Bevin Buchheister, Senior Policy Analyst, NGA

NATIONAL GOVERNORS ASSOCIATION



Develop Action Plan & Wrap Up

Facilitator: Patricio Portillo, Policy Analyst, NGA

NATIONAL GOVERNORS ASSOCIATION